



WKU Educational Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Diddle Arena	2	1	9/20/2016	8:37 AM	Alarm was caused by an excessively dirty detector.				2016-4872
		2	12/24/2016	5:04 PM	Mechanical issue related to weather activated alarm.				2016-6585
Downing Student Union	1	1	9/24/2016	12:47 PM	WKU Maintenance Unit 70 advised a child possible pulled the pull station across from room 1047.				2016-4965
Environmental Science and Technology	3	1	4/28/2016	12:16 AM	Dirty smoke detector				2016-2164
		2	6/30/2016	6:50 PM	Dirty detector				2016-3293
		3	7/1/2016	12:09 AM	Alarm was caused by condensation.				2016-3298
Faculty House	3	1	2/8/2016	10:56 PM	Accidental alarm.				
		2	9/1/2016	11:35 PM	Reason for Alarm resident was cooking and carried his food across room and heat/steam caused alarm to go off.				2016-4545
		3	11/12/2016	5:35 AM	Detector was full of water				2016-5926
Felt House								2016-0697	
Florence Schneider Hall (Gatton Academy)									
Garrett Conference Ctr.	2	1	2/8/2016	5:39 PM	Air handler came on and blew dust into the smoke detector which activated the alarm.				2016-0619



WKU Educational Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Facility	Number of Injuries that required treatment at a Medical	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Jones Jagers	2	2	8/19/2016	8:52 AM	WKU Maintenance was cutting tile inside the building, causing dust to get into the smoke detector which activated the alarm.					2016-4277
Kentucky Building	1	1	6/5/2016	6:54 AM	Sensor went bad, detector replaced.					2016-2833
Learning Center	1	1	11/13/2016	12:41 AM	Dirty smoke detector					2016-5955
LT Smith East	2	1	3/11/2016	8:26 AM	Dirty detector					2016-1220
		2	8/30/2016	9:01 AM	Smoke coming from inside 2nd floor concourse, gas can used for power washer caught on fire.					2016-4491
LT Smith West										
Mass Media	3	1	3/14/2016	1:08 AM	Dirty detector underneath the floor					2016-1275
		2	7/14/2016	5:24 AM	Extremely dirty smoke detector					2016-3564
		3	8/9/2016	10:15 PM	Smoke detector under the floor in the main frame room connected to FM 200, was dusty and dirty causing alarm.					2016-4081
Music Recital Hall										
Old Mall/ ICSET										
Parking Structure 1										
Parking Structure 2	1	1	8/13/2016	6:31 PM	Car fire on 1st level ramp					2016-4169
Parking Structure 3	1	1	4/13/2016	8:28 AM	drilling dust from contractors on site					2016-1865

WKU Educational Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Facility	Number of Injuries that required treatment at a Medical	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Potter Hall										
President House										
Preston Center	1	1	12/7/2016	7:19 PM	Pipe burst on basketball court activating waterflow alarm.					2016-6336
Publication Building										
SC/Carrol Knicely	1	1	7/17/2016	12:22 PM	Moisture build up in number 5 air handler duct detector.					
Service Supply	2	1	8/26/2016	1:13AM	A faulty I M was replaced.					2016-4404
		2	8/30/2016	1:56 PM	Faulty IM swtich					2016-4495
Snell Hall	2	1	6/23/2016	5:22 PM	Dirty detector in basement elevator lobby					2016-3158
		2	7/18/2016	1:14 PM	Condensation inside the duct detector in basement					2016-3663
Tate Page	1	1	3/22/2016	2:07 PM	Mulch fire					2016-1461
Thompson Center	1	1	3/2/2016	2:49 PM	Lithium battery explosion					2016-1071
VanMeter Hall	1	1	10/13/2016	9:03 PM	Fog machine set off alarm					2016-5356
Wetherby Adm. Building										
WKU Police										
<b>Miscellaneous</b>										
Alumni Square Garage	1	1	2/15/2016	3:04 AM	Busted pipe.					2016-0788
Outside IW Fine Arts Center	1	1	2/18/2016	11:27 PM	Dumpster Fire					2016-

WKU Educational Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
University Boulevard / Creason St Intersection	1	1	6/8/2016	6:31 PM	Smoke and Flames observed coming from around a light pole at the corner of Creason Lot.				2016-2883
Dumpster Behind Rodes Harlin State Street/College Heights Blvd	1	1	11/20/2016	11:48 AM	Smoke coming from a dumpster used for recyclable materials. Mulch Fire				2016-4080
<b>TOTAL:</b>	51								