

WKU Residential Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Barnes Campbell Hall	2	1	1/13/2016	4:52 PM	Student was cooking and left area. The suppression system was activated by fire on stove.				2016-0223
		2	2/2/2016	5:17 AM	Vandalism caused flooding in bathroom on the 3rd floor and water ran down stairwell to 2nd floor, and shorted out flow switch which activated actual fire alarm.				2016-0517
Bates Runner	1	1	8/13/2016	6:33 AM	Alarm was activated while fogging for bugs at Subway				2016-4157
Bemis Lawrence Hall									
Douglas Keen Hall	6	1	2/20/2016	3:34 PM	Burnt food in microwave in room.				2016-0889
		2	3/21/2016	3:09 AM	Burnt food in second floor kitchen				2016-1437
		3	3/23/2016	9:08 PM	Burnt popcorn on fourth floor				2016-1483
		4	9/13/2015	2:02 PM	An unknown person set fire to a flyer on the wall. Arson report filed and is under investigation.				2016-5447
		5	11/9/2016	8:07 PM	Burnt food				2016-5877
		6	11/28/2016	8:15 PM	Burnt food in kitchen				2016-6213
		1	4/22/2016	11:09 PM	dirty smoke detector				2016-2067
		2	6/4/2016	6:32 PM	Contractors working inside building, filling up the sprinkler system accidentally set off the fire alarm.				2016-2823

WKU Residential Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Florence Schneider Hall	6	3	6/6/2016	10:37 PM	Alarm was caused by too much dust floating around and the cover on one detector had slipped off causing dust to enter and set off alarm.				2016-2862
		4	6/10/2016	2:30 PM	Alarm was caused by maintenance working on the system				2016-2925
		5	8/5/2016	2:55 PM	Alarm was caused by contractor sweeping, activating smoke detector				2016-3988
		6	12/12/2016	12:55 AM	Water leaking in from outside soaked detector.				2016-6391
Gilbert Hall									
Hugh Poland Hall	7	1	3/17/2016	12:49 PM	Excessively dirty detector				2016-1365
		2	3/26/2016	11:10 PM	Burned popcorn				2016-1541
		3	4/5/2016	6:04 AM	Act of Arson; Four pizza boxes were placed on each of the burners, which were turned on high heat. Suppression system prevented fire and smoke filled the kitchen.			400	2016-1727
		4	5/18/2016		Alarm was caused by members of HRL spray painting KILZ on ceiling tiles causing the spray to activate smoke alarm.				2016-2540
		5	9/14/2016	10:50 PM	Alarm was caused by an excessively dirty detector.				2016-4779
		6	9/23/2016	2:48 AM	Someone discharged a fire extinguisher on the sixth (6) floor.				2016-4931

WKU Residential Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
		7	10/24/2016	4:26 PM	Vapor from e-cigarette set off alarm.				2016-5574
1355 Kentucky St. Apts	1	1	7/27/2016	1:50 PM	No alarm present. Resident used fire extinguisher to extinguish fire inside oven caused by leaving pizza boxes inside.				
McCormack Hall	11	1	3/3/2016	1:08 AM	Activation of smoke detector by an aerosol spray.				2016-1078
		2	10/7/2016	8:45 AM	Dirty detector				2016-5211
		3	10/5/2016	10:33 AM	Contractor cleaning and dust set off alarm.				2016-5194
		4	10/27/2016	9:42 AM	Burnt food.				2016-5621
		5	11/14/2016	8:23 PM	Pull station activated by unknown person				2016-5979
		6	11/14/2016	8:53 PM	Pull station activated by unknown person				2016-5981
		7	11/14/2016	11:24 PM	Pull station activated by unknown person				2016-5983
		8	12/4/2016	5:14 AM	Pull station activated by unknown person				2016-6292
		9	12/5/2016	1:21 AM	Malicious activation of pull station 4th floor.				2016-6301
		10	12/5/2016	3:32 AM	Pull station activated by unknown person				2016-6302
		11	12/8/2016	4:37 AM	Pull station activated on 4th floor.				2016-6339
Meredith Hall									
Minton Hall	2	1	10/12/2016	6:07 PM	Burnt food on the 9th floor.				2016-5326
		2	10/21/2016	6:14 PM	Burnt food on 2nd floor stove.				2016-5518

WKU Residential Buildings Fire Log 2016	Total Fire Alarms in Building for calendar year 2016	Fire Alarm Number	Date of Fire Alarm	Time of Fire Alarm	Cause of Fire Alarm	Number of Injuries that required treatment at a Medical Facility	Number of Deaths related to Fire*	Value of Property damage caused by Fire	Incident Number
Southwest Hall	1	1	6/21/2016	12:54 PM	Alarm was caused by pull station had a broken latch on it, work crew in the building bumped it and activated the alarm system.				2016-2119
Zacharias Hall									
\$100 Solution House	1	1	4/22/2016	12:39 PM	Dirty smoke detector				2016-2123
*- Number of Deaths Related To Fire includes deaths within one year of injuries sustained as a result of the Fire.									

TOTAL:

52

kitchen alarms 7